

BEFORE THE NEBRASKA DEPARTMENT OF ENVIRONMENTAL QUALITY

THE CASE OF ) Case No. 2957  
**Bernard Petska** )  
SW1/4, SW1/4, SEC. 30, TOWNSHIP )  
19N, RANGE 13W )  
Valley County, Nebraska ) AMENDED ADMINISTRATIVE ORDER  
Onsite Wastewater Treatment System )  
F.I.D. # 86798 )  
Respondents )

The Department of Environmental Quality (DEQ) and the Respondent, Bernard Petska, voluntarily enter into this Amended Administrative Order. The previously entered administrative order in this case shall stay in full force and effect, except paragraph 6, which is amended to the following:

6. The Respondent shall perform the following activities:

- A. Immediately eliminate any discharge of wastewater to the existing drain field.
- B. By June 1, 2010, the existing distribution line from the tank to the drain field must be entirely removed or completely filled with a permanent substance that will render it inoperable and permanently unusable.
- C. The holding tank must be watertight and meet all Title 124 requirements, including the Chapter 11 requirements for holding tanks. (Chapter 11 covers size and alarm requirements for holding tanks. If they remove the distribution piping and cap the tank outlet, it should be watertight.)
- D. Work must be done by a certified Installer.
- E. Notify the Onsite Program at least 5 working days in advance of when the work will be done and provide the Department the opportunity to be present when the work is being done.
- F. The Installer must register the system (holding tank) (completed Form G and appropriate fees). The installer must include with the registration a description of the

By: /s/ Steven J. Moeller  
Steve Moeller, Attorney for  
Department

/s/ Bernard Petska  
Bernard Petska

IT IS ORDERED and agreed this 29 day of January, 2010.

By: /s/ Michael J. Linder  
Michael J. Linder  
Director  
Department of Environmental Quality